



# Transformer Technical Data Sheet

EGTRA/TEC/01/02  
10th RAMADAN CITY - EGYPT

Date	: Thursday, October 11, 2020	Registration No	: ORN 200116
Customer / Project Name	: <b>ABB Cote D'Ivoire</b>	ABB Design Code	: TOA-1250/36XFSR

## General Specification

Transformer Type	3-Phase Distribution Oil Immersed Transformer		
Oil Filling	Class A Mineral Oil acc. To IEC 296		
Standard	IEC 60076		
Installation	Outdoor		
Type Of Oil Sealing	Hermetically Sealed		
Phase	3		
Frequency [Hz]	50		
Vector group	Dyn11		
Type of cooling	ONAN		
Terminals Protection degree	IP00		
Altitude (below -) [m]	1000		
Ambient Temperature [ °C]	40		
Average Oil Temperature rise [K]	60		
Average Winding Temperature rise [K]	65		
Winding	Primary	Secondary	
Rated Power [kVA]	1250	1250	
Rated Voltage [V]	33000	410	
Maximum system Voltage [kV]	36	1.1	
BIL (Basic Impulse Withstand Level) [kV]	170	10	
Power Frequency withstand Level [kV]	70	3	
Tapping (Off circuit tap changer)	+2/-2 steps X 2.5 %	-	
Connections	DELTA	WYE	
Insulation class	A	A	
Conductor Material	Aluminum	Aluminum	

## Guaranteed Performance Data @75°C

No load loss [W]	2200	(+15% Tolerance)
Load loss [W]	14000	(+15% Tolerance)
Total loss [W]	16200	(+10% Tolerance)
Impedance [%]	6	(±10% Tolerance)

## Overall Dimension & Weight

Length [mm]	1765	(±10% allowance)
Width [mm]	1139	(±10% allowance)
Height [mm]	1792	(±10% allowance)
Oil Weight [kg]	658	(±10% allowance)
Total Weight [kg]	3278	(±10% allowance)

## Accessories

- Rating plate , Lifting Lug , Drain Plug , Tanking Earth , Off-Load Tap Changer	
- Bi-directional Rollers-(Diameter,C-C)	: 160 mm, 820 mm
- High Voltage Bushing	: Plug In 36KV/400A
- Low Voltage Bushing	: Bus Bar Bushing - BT 1/2000A
- Pressure Relief Device	
- DGPT2	

## Notes

- Other accessories which are not mentioned in the above statements are not included.
- Tests: Routine tests according IEC standard.
- The tolerances for all guaranteed values are subject to IEC standard.
- If no other standards or rules are specified, transformers are manufactured according to IEC standard.

Issued by : Ashraf Mobarak

Signature : ARM

Site web : [www.aljawad.ci](http://www.aljawad.ci) | Email : [aljawad@aljawad.ci](mailto:aljawad@aljawad.ci)

(+225) 27 21 25 35 27

